

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1220439

**Product:** Empty enclosure for switchgear assemblies

**Type:** RIE

**Rating:** 600 x 600 x 1645 mm, IP54

**Ordering firm:** Tritón Pardubice, spol. s r. o.  
Starý Mateřov 130, 530 02 Starý Mateřov, Czech Republic

**Manufacturer:** Tritón Pardubice, spol. s r. o.  
Starý Mateřov 130, 530 02 Starý Mateřov, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 221572-01/01 of: 06.09.2022

**A sample of the product was found to be in conformity with:**  
ČSN EN 60529:1993+A1:2001+A2:2014, ČSN EN 62208 ed. 2:2012 cl. 9.8

**Other data:**

**The validity of the certificate is limited to:** 11.09.2025

12.09.2022

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



221572-01