

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

## CERTIFICATE

No.: 1240274

**Product:** Switchboard enclosures

**Type:** RNA, SNA

**Rating:** IP20, IK05 for RNA, IP30, IK06 for SNA, indoor use

**Ordering firm:** Tritón Pardubice, spol. s r. o.  
Starý Mateřov 130, 530 02 Starý Mateřov, Czech Republic

**Manufacturer:** Tritón Pardubice, spol. s r. o.  
Starý Mateřov 130, 530 02 Starý Mateřov, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 241155-01/01 of: 22.05.2024

**A sample of the product was found to be in conformity with:**  
ČSN EN 62208 ed.2:2012

**Other data:**

**The validity of the certificate is limited to:** 05.06.2027

06.06.2024

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



241155-01