F 540-028-38EN (2019-12-19) (F540 028 38EN)

## **TYPE CERTIFICATE**



Registration number 13.268.298

issued for the manufacturer:

Tritón Pardubice, spol. s r. o. č.p. 130 530 02 Starý Mateřov Company Registration No.: 60110422

for the product:

Name: Wall switchboard

Type designation: RUA

Modification: See the annex

Place of the production: Tritón Pardubice spol. s r. o., Starý Mateřov 130

at which the certification has been conducted pursuant to certification scheme SCH3 – based on ISO/IEC 17067, scheme 3 and in accordance with TÜV SÜD Czech certification system. The results are stated in Evaluation report file No. 13.268.349 from 22.02.2021.

The product type mentioned above fulfils the applicable requirements of the following regulations/standards which were the basis for its evaluation:

ČSN EN 62208 ed.2:2012 (EN 62208:2011)


This certificate is valid till: 05.03.2026

Details and validity conditions are stated in the annex which forms an integral part of this Certificate and contains 1 page.

This certificate is issued on the basis of voluntary certification, and it does not substitute outputs of the authorized or notified body.

Prague, 05.03.2021






- 1. The product specimen was entered for evaluation and type certification on 30.06.2020.
- 2. The Certificate was issued on the basis of the documents provided by the client:
- Application for certification from 30.06.2020
- The assessment of factory production control was performed at the product manufacturer concentrating on elements ensuring the continuation of product conformity with certification requirements.
- 4. Detailed technical data characterizing the product type:

Modification RPA	Height [mm]	Width [mm]	Depth [mm]	Weight [kg]
06-AS4	370	600	395	14,2
09-AS4	500	600	395	17,3
12-AS4	635	600	395	20,3
15-AS4	770	600	395	22,0
18-AS4	900	600	395	26,6
06-AS5	370	600	495	16,1
09-AS5	500	600	495	19,5
12-AS5	635	600	495	21,7
15-AS5	770	600	495	26,é
18-AS5	900	600	495	29,1
06-AS6	370	600	595	18,9
09-AS6	500	600	595	21,3
12-AS6	635	600	595	26,0
15-AS6	770	600	595	28,5

Degree of protection - IP30

Capacity - 30kg



- Is stated in the Evaluation report No. 13.268.349 from 22.02.2021.
- 6. Validity Conditions
- The certificate shall apply only to its holder and products and production places mentioned therein.
- The transfer of the certificate by its owner to third parties is inadmissible as well as the use
  of certificate by third parties.
- TÜV SÜD Czech shall be notified forthwith of any product modifications compared to the certified specimen. This fact may cause the certificate continuation dependent on an additional conformity evaluation.
- TÜV SÜD Czech shall supervise the proper functioning of the Quality System at the manufacturer within a once a year period on the basis of a concluded contract about the controlling activity.
- The certificate can be renewed on request.
- The certificate shall only be reproduced complete including all the annexes.
- The right to use TÜV SÜD Czech certification mark was not established to the certificate.
- The certificate holder commits to keep records of all the relevant complaints concerning the conformity of the products with the requirements of regulations and standards and make those records available to the certification body TÜV SÜD Czech.
- Not specified items (advertising, use of certification mark and certificates) are governed by the General Conditions for Product Certification, as amended.